

NFRC Product Certification Authorization Report



Manufacturer: Sunoptics Prismatic Skylights **Product Series:** Signature² and Pyramid Skylights **Simulation Lab:** SATI **Initial Cert. Date:** 10/29/2010
Street: 6201 27th Street **Product Type:** SKDM **Sim. Report #:** A2457.01-301-45 **Re-Certification Date:**
City/State/Zip: Sacramento, CA 95822 **Air Leakage:** **Sim. Report Date:** 09/08/2010 **Revised Date:** 09/08/2010
Print Date: 10/29/2010 **Test Date:** 09/02/2010 **Expiration Date:** 09/02/2014

CPD Number: SOS-A-2			IA: American Architectural Manufacturers Association												
Status	Product Num.	Manufacturer Code	Frame/Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res.
	00001-00001	Pyramid Double Dome	AI/NA	1			N		N		CL	0.75	0.51	0.00	41
	00002-00001	Pyramid Triple Dome	AI/NA	1			N		N		CL	0.64	0.39	0.00	41
	00003-00001	Signature ² Double Dome	AI/NA	1			N		N		CL	0.74	0.42	0.00	41
	00004-00001	Signature ² Triple Dome	AI/NA	1			N		N		CL	0.62	0.33	0.00	41
	00005-00001	Signature ² Double Dome over Single Flat	AI/NA	1			N		N		CL	0.46	0.42	0.00	52
	00006-00001	Signature ² Double Dome over Double Flat	AI/NA	1			N		N		CL	0.37	0.39	0.00	52
	00007-00001	Signature ² Double Dome over Triple Flat	AI/NA	1			N		N		CL	0.28	0.35	0.00	51

Baseline Information

Test Lab	Test Date	Test Size	Tested U-Value	Standard U-Value	Test Report Number
TATF	09/02/2010	1311 mm x 1311 mm	0.296	0.292	A2327.01-301-46

Comments:

I hereby certify that all requirements for NFRC Certification Authorization have been met and that the above information is true and correct, to the best of my knowledge.

Authorized IA
Signature: _____